

**Response of  
Wisconsin Power and Light Company  
to  
The Public Service Commission of Wisconsin  
Data Request No. 1.13**

Docket Number: 05-CE-137  
Date of Request: January 29, 2009  
Information Requested By: Ken Detmer  
Date Responded: February 16, 2009  
Author: Eric Guelker  
Author's Title: Mgr Environmental Services  
Author's Telephone No.: (608) 458-8163  
Witness: (If other than Author)

---

**Data Request No. 1.13:**

p. 25 Table 4: Beginning in 2013, should the level of NO<sub>x</sub> be .15 instead of .20 for Edgewater 3 under all 3 scenarios?

**Response:**

No, it should not. The emission rate levels identified in the column referenced reflect the expected emission rate from the unit (in lb/mmBtu) for the year identified. These emission rate levels are not the unit emission rate limit specified in the Reasonably Available Control Technology (RACT) rule. The column to the left of this column titled "Estimated Facility Limit" is the facility emission rate limit derived from the unit emission rate limits specified in the RACT rule combined with the estimated heat input of the units included in the facility averaging plan.